


ASSEMBLY AND INSTALLATION INSTRUCTIONS

C0249

WARNING: TO AVOID RISK OF ELECTRICAL SHOCK, BE SURE TO SHUT OFF POWER BEFORE INSTALLING OR SERVICING THIS FIXTURE.

NOTE: 1. Before installing, consult local electrical codes for wiring and grounding requirements.
2. READ AND SAVE THESE INSTRUCTIONS.

Hardware Package (included):




Installation Steps

Turn off the power at fuse or circuit box







1. Attach the mounting strap unit (A) to the outlet box using two mounting screws (B).
2. Screw 185mm long rods and 160mm short rods to the threaded pipes of fixture according to the figure.
3. Pull out the source wires from the outlet box. Make wire connections using wire connector (C) as follows:
 - Connect the black wire from the fixture to the black wire from the power source.
 - Connect the white wire from the fixture to the white wire from the power source.
 - Attach the fixture ground wire to the mounting strap unit (A) with the green ground screw, then connect it to the house ground wire with a wire connector (C).Carefully put the wires back into the outlet box.
4. Attach the fixture canopy to the mounting strap unit (A) by inserting the fixture mounting screw, then secure it with two bolt nuts (D).
5. Install bulbs (not included).
Check relamping label at socket area or packaging for maximum wattage allowed.


Turn on the power at fuse or circuit box



The following parts are available for re-order if damaged or missing.

Spare Parts List:

 Mounting Strap Unit (A)	 Mounting Screw (B)	 Wire Connector (C)	 Bolt Nut (D)
 Short Rod 160mm 3230RD	 Long Rod 185mm 3229RD	← Assembly Kit 6280MM (1SET)	



A: 17"
B: 11-1/2"

1 Year Warranty

Vaxcel warrants all of our products against defects in workmanship and finishes for one year following the date of shipment.

Exclusions: This warranty does not include the failure of products from extreme acts of nature; environmental conditions not suited for the products intended use; operation in temperatures outside of the range specified in the instruction manual; usage with improper power supply, power surges or dips. For coastal locations, some corrosion is considered normal for the environment.

Vaxcel reserves the right to repair, replace or issue a credit for any properly installed product, provided it is returned per RMA instruction. This warranty is limited to the cost of the product only and does not extend to transportation, installation or replacement costs.

How can warranty service be obtained?
info@vaxcel.com
1-800-482-9235